

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer LEM INTERNATIONAL SA  
152 Route du Nant-d'Avril  
1217 MEYRIN  
Switzerland

Measuring instrument A **static DC energy meter**

Type : DCBM 100  
Manufacturer's mark or name : LEM  
Reference voltage : 150 VDC ... 1.000 VDC  
Reference current : 16 A  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T12552 revision 1;  
- Documentation folder T12552-2.

Valid until 26 June 2033

Initially issued 26 June 2023

Remarks This revision replaces the earlier version(s), including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
22 December 2023

Certification Board